## SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA 22.2, #8 TUV APPROVED: EN60950

## OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 30 AMP/55°C, 80 VDC

LINE FREQUENCY: DC
MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND: N/A mA @ 120V 60Hz N/A mA @ 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +55°C @ RATED CURRENT, I\_r. IN AN AMBIENT, T\_0, HIGHER THAN 55°C, THE MAXIMUM OPERATING CURRENT, I\_0, IS AS FOLLOWS: I\_0 = I\_r  $\sqrt{85-T_0}$ 

# RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES I<sub>r</sub> FOR 8 SECONDS

# TEST SPECIFICATIONS:

INDUCTANCE: 0.701mHNDMINAL

CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND: 0.093 µF ±20% LINE TO LINE: 2.024 µF ±20%

DISCHARGE RESISTOR: 0.165Mn L/G AND L/L I.R.

ND DISCHARGE RESISTOR: 6000M\(\text{\alpha}\) (MIN.) @ 100VDC,

20°C AND 50% RH

CATALOG # 30DCB6

APPRVD. DDMMMYY

11MARO3

EC#


0631-0093-03

## RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 2250 VDC FOR 1 MINUTE LINE TO LINE: 1450 VDC FOR 1 MINUTE

# FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



50	50	JΩ(	MIN	IMU	M )	INZI	ERT	ΙΠΝ		22	
FREQUENCY MHz	.01	. 05	0.1	. 15	0.5	1	3	5	10	30	
COMMON dB		4	15	23	47	59	64	56	44	36	
DIFF. dB	7	22	28	31	32	59	56	51	41	28	

THIRD ANGLE PROJECTION	
UNLESS OTHE	 ECIFIED,

UNLESS OTHERWISE SPECIFIED, TOLERANCE TO BE ±.025 MATERIAL & FINISH: AS SUPPLIED

This document	is proprietary to CORCOM INC.
and is not to	be reproduced nor used for
manufacturing	purposes except on CORCOM'S
prior written	consent.

tyco	Elec	tronic	cs	#cor	C	
	844 E.	ROCKLAND	RD.	LIBERTYVILLE	ΙL	60048

## POWER LINE FILTER

	CAD FILE: G:	\CD\30DCB604	TYCO # 2-1609074-5	
•	SCALE: NITS	DATE:	CATALOG NO.	REV.
	1/1.7	10-30-00	aanana	4
	DRW. BY:	DRIG:	30DCB6	4
	PJU	PJ0		